CLEAR WATER CLEAN ENVIRONMENT





IDA SAN CANDIDO-SESTO



IDA WASSERFELD



IDA BASSA VAL PUSTERIA



ARA PUSTERIA

Floronzo / Tobel 54 I-39030 San Lorenzo (BZ) Tel. +39 0474 479601 Fax +39 0474 479641 info@arapustertal.it www.arapustertal.it





CLEAR WATER CLEAN ENVIRONMENT

COMMISSIONED FROM THE MUNICIPALITY OF VAL PUSTERIA

ARA PUSTERIA

Catchment area: 2.168 km²

Lenght sewerage system: 131,94 km

Inhabitants equivalent: 300.000 EW_{bia}

Yearly quantity of sewage: 13.090.000 m³/a

Sludge quantity: 10.630 tons/a









Municipality of Valle Aurina



Municipality of

Selva dei Molini

Municipality of Corvara



Municipality of Valle di Casies



Municipality of Chienes



Municipality of Mareo



Municipality of Villabassa



Municipality of Municipality of Valdaora Perca



Municipality of Falzes



Braies





Municipality of Rasun-Anterselva



Municipality of

Rodengo

Municipality of

Rio di Pusteria



Municipality of Campo Tures



Sesto



Municipality of San Lorenzo di Sebato



Municipality of Terento



Municipality of Monguelfo-Tesido







Gasometer

1111

Septic tank

Septic tank

Side gallery

Building operational

Sludge dryer

Central gallery

Side gallery

Termal treatment plant

IDA TOBL San Lorenzo di Sebato

CONSTRUCTION PROGRESS

Start of construction: March 1991

Completion: December 1995

Beginning of aperation and function tests: January - June 1996

In operation since: 3. July 1996

Discharge of sewage flow: June 1996

Valle Aurina: June 1997 Bassa Val Badia: December 2000

OPERATING DATA

Yearly quantity of sewage: $6.500.000 \text{ m}^3/a$ Sludge quantity: 8.000 Tons/aProduced electrical energy: 3.500.000 kWh/aEfficiency: $BOD_5 = 99\%$ COD = 96%N = 87%

 $\frac{N_{tot}}{P_{tot}} = 87\%$





A TECHNOLOGICAL MIRACLE IN THE MOUN-TAIN. IT IS WORTH A VISIT – AND NOT ONLY A VIRTUAL ONE!

For the cavern construction, 200,000 m³ of solid material were extracted from Mt. Tobl, for which the plant was also named. The construction required 740 km of drilling and 220 tonnes of explosive agent. The underground galleries' cross section is twice as big as an underground motorway tunnel's cross section. The total sewage line, the ventilation system centre, as well as the dosing apparatuses are installed in the galleries. Also the digestion tower, with exception of the gas area, is built into the rock. Only the remaining sludge line, the total gas line, the sludge drying plant and the thermal waste recycling plant are in the operational building on the surface.

- **1...** Inlet gallery
- 2... Central gallery
- **3...** Connecting gallery
- **4...** Side gallery
- 5... Septic tank
- 6... Gasometer
- 7... Building operational
- 8... Sludge dryer
- **9...** Termal treatment plant



CAVERN

Preliminary clarifier



Central Gallery Consisting of:

Screening plant Aerated grit chamber Skip-raked fine bar screen Pre-thickeners Technical rooms

Technical rooms



Technical data Central Gallery:

Gallery Lenght: approx. 325 m Full section: 65 - 180 m² Excavation volume: approx. 35.000 m³



Side Galleries Consisting of:

Preliminary clarifier Denitrification basin Nitrification basin Deammonification Final clarifier

Preliminary clarifier



Technical data Side Galleries:

Gallery Lenght: approx. 325 m Full section: 190 - 200 m² Excavation volume: approx. 75.000 m³

Cavern

Technical data:

Excavations total: approx. 200.000 m³ Surface support: approx. 50.000 m² Concrete Spritz: approx. 12.000 m³ Anchors: approx. 50.000 m Welded Steel Mesh: approx. 200.000 kg Quantity of explosives: approx. 150.000 kg

Total Cavern

Requirements:

Concrete regularization: approx. 2.000 m³ Concrete structures: approx. 22.000 m³ Steel Formwork: approx. 1.500.000 kg Formwork: approx. 50.000 m²



PERFORMANCE DATA

Capacity:	150.000 inhabitants equivalent
each	33% population
	47% from tourism
	20% from industry
Loads:	7.800 kg BOD ₅ /d
	12.000 kg COD/d
	1.560 kg N _{tot} /d
	390 kg P _{tot} /d
Sewage flow:	Daily quantity of sewage 15.000 m³/d
	Dry weather flow 570 l/s
	Wet weather flow 1.140 l/s
Quantity of sludge:	row 1.000 m³/d
	7.000 kg/d dried matter
	After primary sludge treatment 150 m ³ /c
	After sludge dewatering 20 m³/d
Tot. effective volume:	meccanical – biological
	treatment 38.440 m ³
	Sludge treatment 5.860 m ³
Tot. effective volume:	Gallerys: 200.000 m ³
	TRA + TVA: 5.815 m ³
	Service building: 12.550 m ³

TECHNICAL DATA SEWERAGE SYSTEM

Catchment area: 1.176 km²

Lenght: 78,32 km

Perca

La Val

Diameter: 200 mm – 1.200 mm

Material: SB, GFK, SZ, PVC

Quantity drains: 1.147

Quantity measuring stations: 14

Quantity pump stationes: 0

TECHNICAL DATA

mergency screening plant:	
3 bar-screen	
Bar spacing 3 mm	
Screening plant:	
2 bar-screen, wide 1.200 mm	
Bar spacing: 15 mm by 2 screenings	
vash presses integrated and bagging decive	2
kip-raked fine bar screen:	
2 Aqua - Guard screens, wide 1.500 mm	
Bar spacing: 6 mm by 2 screenings	
vash presses integrated and bagging decive	2
Aerated grit chamber: 2-line; each line	
Grit chamber cross section 6,50 m ²	
/olume 200 m ³ ; T = 12 min by Q_t	
Grit washer Q _m = 20 l/s	
Preliminary clarifier:	
I-line, each line	
Vide 7,6 m; Lenght 13,50 m	
Vater depht 2,75 m	
/=260 m ³ ; t = 0,23 h by Q _t	
ransverse flowed, sludge scrapers	
Biological basin: 4-line, each line	
Denitrification basin	
basin = 3.250 m ³	
Nitrification basin = 6.350 m^3	
Number of slabs-Messner: 92 per basin	
Number of slabs-Messner: 156 per basin by	
ntermittend operation	
/olume - Denitrification 9.750 m ³	
/olume - Nitrification 19.050 m ³	
/olume - Total VN + VD = 28.800 m ³	
3x 5 Horizontal agitator	

Recirculation pumps 12x Q = 140 l/sBlowers: 2 compressors, each 5.000 Nm³/h, 132 kW 2 compressors, each 2.500 Nm³/h, 70 kW Deammonification: 1 basin batch treatment = 1.514 m^3 1 surnatant water accumulation = 1.400 m^3 4 horizontal agitator 1 compressor, 1750 Nm³/h 274 kg NH4-N/d Final clarifier: 8-line, each line Lenght / Wide= 45/7,6 m Water depht 4,50 m; $V = 2x 1.400 \text{ m}^3$ Longitudinal flowed, chain&flight scrapers **Phosphate Precipitation:** Simultaneous precipitation Lime milk dissolving station For regulation pH-value in biological basin Quantity of row sludge: Row sludge 1.000 m³/d by 7.000 kg TS/d and $150 \text{ m}^3/\text{d}$ after primary sludge pretreatment **Pre-thickeners:** 4 pieces 4.9 m x 4.9 m: Volume $4 \text{ x} 90 = 360 \text{ m}^3$ Rabble rakes, sludge water separation Secondary sludge pretreatment: Screencloth: $Q = 36 \text{ m}^3/\text{h}$ Conditioning by polyetectrolytes Strainpress: $Q = 20 \text{ m}^3/\text{h}$ **Digestion chambers:** 2 pieces Cylindrical tank D = 14,00 m; H = 25,00 m Usable vol. = 1.800 m^3 ; digestion time 30 day Circulation by biogas + pumps

Post thickeners: 2 pieces Volume $2x 500 = 1.000 \text{ m}^3$ **CO-substrates tank:** Volume x 500 m³ Gasometer: Cylindrical enclosure in steel construction Ring membrane gas accumulator; 40 mbar Usable volume: 1.500 m^3 ; H = ca. 15,0 m Gas flare plant: Capacity = $150 \text{ m}^3/\text{h}$ Sludge dewatering: 3 screw press: $Q = 3 - 5 \text{ m}^3/\text{h}$ Conditioning by polyetectrolytes Sludge storage: tank: 80 m³ loaded by screw conveyor Ventilation system: Biofilter for exhaust air: $Q = 28.000 \text{ m}^3/\text{h}$, Area: 320 m² V = 800 m³ Gas engine plant: 3 pieces each $P_{tot} = 420 \text{ kW}$; $P_{ol} = 140 \text{ kW}$; $P_{\rm th} = 233$ kW for methangas und biogas 1 piece each $P_{tot} = 743 \text{ kW}; P_{el} = 330 \text{ kW};$ $P_{\rm th} = 413$ kW for biogas Treatment of industrial water: Sand filter and UV-system (UV- Anlage): 20 l/s Sludge drying plant (strip drier): Capacity evaporation: 2 Tons H₂O/h $EW_{bio} = 430.000$ 24.000 Tons/a Thermal waste recycling plant: Pyrolysis revolving drum Capacity: 550 kg/h pellets from the drying plant Dry flue gas cleaning









SEWAGE TREATMENT LINE

The sewage treatment plant was dimensioned and engineerized for a 150.000 inhabitants equivalent capacity, in the way to satisfy the needs of population in local areas, of tourism, of industry and artisan shipment, guarantying in the meanwhile higher levels in guality, with the maximum efficiency in organic pollutant load knocking down and phosphoric and nitrogen components strong reduction. The target of sewage treatment is reached with physical, biological, chemical and biochemical processes. The mechanical sewerage, with a 25% organic load reduction efficiency, is assured by a spire screen, by aerated grit chamber, bar-screens and primary clarifier. After that, the sewage treated mechanically cross a series of 6 falls: in the first two, in totally oxygen absence, the nitrous compounds reduction is realized (denitrification), while in the following 4 falls, the bigger

ones, atmospheric oxygen is injected to permit la biodegradation of organic compounds and nitrous compounds oxidation (nitrification). The recycle of vented sewage, of actives sludges and the regulation of oxygen concentration, permit the creation of an ambient in which microorganisms and various nature batteries may easily do the proper work of degradation of pollutant load. These microorganisms, in bow structures, are the actives sludges that are separated by sedimentation in the big secondary clarifier. The last reduction of phosphoric compounds is obtained by simultaneous precipitation (adding chemicals agents).

The water's superior layer, now purified, flows out on toothed threshold, is analyzed by a measurement and metering station (for quality and flow rate), and flows out into Rienz river.

GAS & SLUDGES TREATMENT LINE

The sludge coming from the first clarifiers (primary sludge) is thickened mechanically by a rotating drum. The sludge is now eliminated from secondary clarifiers and thickened mechanically by screencloth. The pre-thickened sludges are now reached at a temperature of 40°C approx and digested into an anaerobic digestion chamber. The sludges, now stabilized and neutrals, are dried with 3 screw press.

During the digestion process, the microorganisms transforming the organic compounds on CO_2 and methane with high energetic content, available for thermal heating of digestion chambers and for factory heating. To take a solution at the gas over production, in the ARA Pustertal plant is provided a storage gas tank.

The gas line is composed by: gasometer, gas flare, heater and 4 cogeneration groups.

are,

GES IREAIMENI LINE

















SLUDGE DRYER

The dewatered sludge of ARA Pustertal and ten other municipal waste water treatment plants is dried to granulate within a belt dryer. The water content is decreased from 72 – 82% within the dewatered sludge to 4 – 5% within the granulate. 40 containers (net weight 12,5 metric tons) are reduced to 8 – 10 containers every week. This ia a weight reduction of 75 – 80% Conveyor screws will bring the dewatered sludge to the belt dryer. At 140°C the water is evaporated. The energy to heat the circulating air is generated by the thermal treatment plant.



THERMAL TREATMENT PLANT

The dehydrated sewage sludge is mineralized within the thermal treatment plant. This step is closing the cycle of the sewage sludge.

24.000 metric tons of dewatered sludge are reduced to approximately 2000 metric tons of ash. This reduces truck transporting capacity of about 1000 semi-trucks to approximately 80 semi-trucks. The ash is recycled and used to cover landfills.

The thermal treatment plant is a two stage rotary kiln. First stage is a pyrolysis process at 200-400°C. second stage is an oxidation process at 400-600°C. Flue gas and pyrolysis gas are oxidized at 850°C within a post combustion chamber. The heat recovery system takes out the energy from the flue gas to be used within the drying process. A bag filterhouse with a dry neutralization guarantees minimum emissions off the process. Continuous clean gas monitoring provides maximum ecological standard of the plant.





VENTILATION SYSTEM

During Tobl plant engineer studies, a special importance matter was the particular attention at stinks emissions monitoring. For this reason, various air treatment plant systems was provided.

Galleries ventilation was dimensioned for an air flow rate of 140.000 m³/h, equal to 1 to 6 air changes per hour. These kinds of applications guarantee a continuous development of oxygen into the galleries. The factory ventilation system was dimensioned for an air flow rate of 14.000 m³/h and guarantee that in the warehouse no one kind of stinks. Another chemical treating plant is positioned into the surnatant water accumulation basin and treats air with no ammonia contents.

The exhausting air coming from the drying plant (15.000 m^3/h) is biologically treated. The air is flowed into a injection condenser, is treated and cooled with biologically treated water and now putted on the 320 m^2 surface bio-filter. Into the bio-filter the air coming from the thickeners (13.000 m^3/h) is also biologically treated.

Periodical Analysis are made by external institutes, guarantying that all atmospheric emissions are under the minimum level.











KEY DATA MAIN COLLECTOR:

Overall length: 131.4	46 km
hafts: 2,136 shafts	
Diameter: Ø 200 – 2	1,100 mm
lean age: 25 years	
pecial structures:	Siphons, pipe bridges,
	drop structures,
	rainwater basins,
	stretches of tunnel

MAIN COLLECTOR

The ARA Pustertal AG operates the five wastewater treatment plants of the optimal catchment area and the associated main collector owned by the wastewater consortium Pustertal. The management contract covers all costs and services incurred, including ordinary and extraordinary maintenance and repair work for the duration of the contracted operating years. The collection and discharge of wastewater from the 28 connected municipalities, with a total area of 2,168 km², takes place via a sewer network with a total length of 131.46 km. Dewatering takes place both in the mixing system as well as in the separation system. The sewer network consists entirely of gravity sewers.

A total of 29 measuring stations are installed across the entire sewer network. The measured quantities are sent online to the respective wastewater treatment plants and from there to Bolzano to the relevant office. All measuring stations are regularly maintained. Radar and ultrasonic measuring systems are used. Three sewer inspectors are operationally responsible for the maintenance and repair of the main collector, the measuring stations, the special structures and the rain basins.

Every year around 10% of the total network is cleaned, which corresponds to about 13 km and thus also complies with regulatory requirements. Damages are detected with TV cameras and then resolved as quickly as possible to ensure the tightness and functionality of the network.



The sewer service is there to advise planning offices and municipalities when it comes to new connections and the laying of pipes and oversees their proper execution.





KEY DATA:

Registered small wastewater treatment plants:	
Imhoff tanks, three-chamber septic	
tanks, one- and two-chamber sys-	
tems, special structures	
carrying out the service: 2	

Sewer cleaning vehicle: 1 gully sucker

WASTE DISPOSAL SERVICE FOR SMALL SEWAGE TREATMENT PLANTS

A small sewage treatment plant is, as the word implies, a small wastewater treatment plant. Its task is to clean domestic wastewater and to separate solids from liquids. The liquids are returned to nature, but the solids are collected and disposed of. Therefore, it is important to introduce only domestic wastewater into such a system.

Since June 2002, municipalities are responsible for the removal and disposal of the sewage sludge

from the individual disposal systems for domestic wastewater.

On 17.08.2015, the Wastewater Consortium Pustertal assigned the removal and disposal of the sewage sludge from the individual disposal systems for domestic wastewater to Ara Pustertal AG.

A database was created, a sewer cleaning vehicle was bought, a driver was hired and the service was launched on 13.07.2016.

For the service to be operated transparently, a work programme is drawn up each year, setting out the time period in which each of the municipalities will be approached. In addition, local residents are contacted and informed by mail and telephone. The quantities of sludge from each disposal system must be registered by law.

The municipalities that have benefited from the disposal service are invoiced on a monthly basis.





IDA SAN CANDIDO-SESTO San Candido

CONSTRUCTION PROGRESS

Start of building:	May 1995
--------------------	----------

Completion: October 1997

Initial operation and functional checks: Nov. 1997 - Feb. 1998

In operation since: 10. February 1998

Induction: waste water San Candido February 1998

waste water Sesto July 1998

OPERATIONAL DATA

Yearly quantity of sewage: $1.150.000 \text{ m}^3/a$ Sludge quantity: 1.100 Tons/aProduced electrical energy: 350.000 kWh/aEfficiency: $BOD_5 = 98\%$
COD = 96%
N = 85%

 $\frac{N_{tot} = 85\%}{P_{tot} = 93\%}$



IDA SAN CANDIDO-SESTO San Candido



MUNICIPALITIES



PERFORMANCE DATA

Capacity:	47.000 inhabitants equivalent
each	25% population
	50% from tourism
	25% from industry
Loads:	1.500 kg BOD ₅ /d
	2.500 COD/d
	225 kg N _{tot} /d
	51 kg P _{tot} /d
Sewage flow:	Daily quantity of sewage 3.200 m ³ /d
	Dry weather flow 141 l/s
	Wet weather flow 256 l/s
Quantity of sludge:	row 182 m ³ /d
	1.300 kg/d dried matter
	After primary sludge treatment 30 m³/d
	After sludge dewatering 5 m³/d
Tot. effective volume:	meccanical – biological
	treatment: 9.050 m ³
	Sludge treatment 1.610 m ³
	70.000 7

Tot. effective volume: 30.000 m³

TECHNICAL DATA SEWERAGE SYSTEM

Catchment area: 160 km² Lenght: 13,35 km Diameter: 400 mm - 1.000 mm

Material: GFK, GU, Beton

Quantity manholes: 269

Quantity measuring stations: 3

Quantity Pump stations: 1

TECHNICAL DATA

Pump s	tation:
--------	---------

2 screw conveyor, 800 mm, Tilt angle 33°; Q_{max} 128 l/s **Emergency screening plant:** 1 bar-screen; Bar spacing 3 mm Screening plant: 2 bar-screen, 700 mm Bar spacing: 5 mm; $Q_{max} = 936 \text{ m}^3/\text{h}$ by 1 screenings wash presses integrated and bagging decive Aerated grit chamber: 2-line; each line Grit chamber: Cross section 2.07 m² Volume 67,2 m³; T = 9 min by Q, Grit washer $Q_{m} = 12 l/s$ Preliminary clarifier: 1-line, Wide 6,0 m; Lenght 18,60 m Water depht 2.35 m $V = 254 \text{ m}^3$t = 0,49 h by Q. Longitudinal flowed, sludge scrapers, Biological basin: 2-line, each line Aerob basin 1 basin = 620 m^3 Anox basin (Denitrification) $2 \text{ basins} = 880 \text{ m}^3$ Aerob basin (Nitrification) = 1.325 m^3 162 pieces membrane diffusers Volume - Aerob basin 1.320 m³ Volume - Denitrification 1.760 m³ Volume - Nitrification 2.650 m³ Volume - Total A + VD + VN = 5730 m^3

6 Horizontal agitator $Q = 16.990 \text{ m}^3/\text{h}$ Recirculation pumps $2 \times Q = 120$ l/s 4 compressors, each: 300/720 Nm³/h, 9,5/19,3 kW **Final clarifier:** 4 basins Lenght/Wide = 37.0/6.0 mWater depht 4,50 m; $V = 4.160 \text{ m}^3$ Longitudinal flowed, chain&flight scrapers **Phosphate Precipitation:** Simultaneous precipitation Quantity of row sludge: Row sludge 182 m^3/d by 2.341 kg TS/d and 41 m^3/d after primary sludge pretreatment **Pre-thickeners:** 1 pieces diameter 7,00 m; Volume = $1x 234 \text{ m}^3$ Rabble rakes, sludge water separation Secondary sludge pretreatment: screencloth, Conditioning by Polyetectrolytes $Q = 30 \text{ m}^3/\text{h}$ **Digestion chambers:** 1 piece Cylindrical tank D = 12,00 m; H = 12,70 mUsable volume = 1.140 m^3 ; digestion time 45 days Circulation by biogas + pumps **Post thickeners:** 1 piece diameter 7,00 m; volume = $1x 234 \text{ m}^3$ Rabble rakes Gasometer: Cylindrical enclosure in steel construction Gas accumulator; Usable volume 490 m³; H = rd. 8,0 m

Gas flare plant: Capacity = $15 \text{ m}^3/\text{h}$ Gas compressor station: 2 compressors Sludge dewatering: 1 screw press, Conditioning by Polyetectrolytes, $Q = 3 - 5 \text{ m}^3/\text{h}$ Sludge storage: Area: 220 m² loaded by screw conveyor Liquified gas installation: Tank V = 25 m^3 (interrated) by evaporator station Ventilation system: Chemical area treatment scrubber From meccanical and sludge treatment: $15\,000\,\mathrm{m}^{3}/\mathrm{h}$ Heating system plant by 2 boiler plants each 350 kW thermal capacity by switching automatically for methane gas or biogas Gas engine plant: 1 pieces each $P_{tot} = 151 \text{ kW}; P_{el} = 50 \text{ kW};$ $P_{tb} = 85 \text{ kW}$ for propane and biogas One emergency power generator $P_{ol} = 185 \text{ kW}$ for propane and biogas Deep well - industrial water: 2 pieces of pumps, each 8 - 12 l/s









SEWAGE TREATMENT LINE

The sewage treatment plant was dimensioned and engineerized for a 47.000 inhabitants equivalent capacity, in the way to satisfy the needs of population in local areas, of tourism, of industry and artisan shipment, guarantying in the meanwhile higher levels in quality, with the maximum efficiency in organic pollutant load knocking down and phosphoric and nitrogen components strong reduction. The target of sewage treatment is reached with physical, biological, chemical and biochemical processes. The mechanical sewage, with a 25% organic load reduction efficiency, is assured by a spire screen, by aerated grit chamber, bar-screens and primary clarifier. After that, the sewage treated mechanically cross a series of 3 falls: in the first one, in totally oxygen absence, takes place the bio-chemical process of partial phosphoric compounds deleting, in the second one, the nitrous compounds reduction is realized (denitrification) while in the last one, the bigger one, atmospheric oxygen is injected to permit la biodegradation of organic compounds and nitrous compounds oxidation (nitrification). The recycle of vented sewage, of actives sludges and the regulation of oxygen concentration, permit the creation of an ambient in which microorganisms and various nature batteries may easily do the proper work of degradation of pollutant load. These microorganisms, in bow structures, are the actives sludges that are separated by sedimentation in the big secondary clarifier. The last reduction of phosphoric compounds is obtained by simultaneous precipitation (adding chemicals agents).

The water's superior layer, now purified, flows out on toothed threshold, is analyzed by a measurement and metering station (for quality and flow rate), and flows out into Drava river.







GAS & SLUDGES TREATMENT LINE

The sludge coming from the first clarifiers (primary sludge) is thickened mechanically by a pre-thickener. The sludge is now eliminated from secondary clarifiers and thickened mechanically by screencloth. The pre-thickened sludges are now reached at a temperature of 38°C approx and digested into an anaerobic digestion chamber. The sludges, now stabilized and neutrals, are dried with a screw press.

During the digestion process, the microorganisms trans-

forming the organic compounds on CO2 and methane with high energetic content, available for thermal heating of digestion chambers and for factory heating. To take a solution at the gas over production, in the San Candido Sesto plant is provided a storage gas tank.

The gas line is composed by:

gasometer, pressurization station, gas flare, 2 heaters and 1 cogeneration groups.







VENTILATION SYSTEM

During San Candido Sesto plant engineer studies, a special importance matter was the particular attention at stinks emissions monitoring. All the stronger sources and ways of stinkness (fine bar screen, aerated grift chamber, clarifier and the entire sewerage treatment plant) are positioned on warehouses with the proper air purification system.

The stink air, until a flow rate of $15.000 \text{ m}^3/\text{h}$, is purified with scrubber at crossing flows system with, storing the thermal energy produced.

COMPONENTS AND POWER

For sewerage system and sludges treatment were provided a total amount of 109 units divided into instrumentation, machineries, for a total amount of power consumption of approx 300 kW; the same items quantity were necessary for heating system, ventilation, air treatment, lightness systems, hydro feed exc. For power plant, control and regulation of all these plants and systems, 25 km of bundles and cables were provided.


IDA WASSERFELD Monguelfo

CONSTRUCTION PROGRESS

Start of construction: October 1993

Completion: September 1999

Beginning of operation and function tests: Oct. - Dec. 1999

In operation since: 16. December 1999

OPERATIONAL DATA

Yearly quantity of sewage: 1.700.000 m³/aSludge quantity: 1.050 Tons/aProduced electrical energy: 660.000 kWh/aEfficiency: $BOD_5 = 99\%$
COD = 95%
 $N_{tot} = 86\%$
 $P_{tot} = 92\%$



IDA WASSERFELD Monguelfo



MUNICIPALITIES









Municipality of Municipality of Valle di Casies

Monguelfo-Tesido

Villabassa

Dobbiaco



PERFORMANCE DATA

Capacity:	40.000 inhabitants equivalent
each	30% population
	45% from tourism
	25% from industry
Loads:	2.400 kg BOD ₅ /d
	3.500 kg COD/d
	350 kg N _{tot} /d
	120 kg P _{tot} /d
Sewage:	Daily quantity of sewage: 5.000 m³/d
	Dry weather flow: 111 l/s
	Wet weather flow 280 l/s
Quantity of sludge:	row 182 m³/d
	1.500 kg/d dried matter
	After primary sludge treatment 30 m ³ /d
	After sludge dewatering 5 m³/d
Tot. effective volume:	mechanical – biological
	treatment 10.870 m ³
	Sludge treatment 1.760 m ³
	74.000 3

Tot. effective volume: 31,000 m³

TECHNICAL DATA SEWERAGE SYSTEM

Catchment area: 390 km² Lenght Hauptsammler: 15,08 km Diameter: 250 mm – 900 mm Material: AZ, STB, PVC, GFK Quantity drains: 263 Quantity measuring stations: 5 Quantity pump stationes: 0

TECHNICAL DATA

Emergency screening plant:
1 bar-screen
Bar spacing 3 mm
Screening plant: 2-line
2 step-screen
Bar spacing: 6 mm; Q _{max} = 1.275 m³/h
by 1 screenings wash presses integrated
and bagging deceive
Aerated grit chamber:
2-line; each line
Grit chamber: Cross section 4,51 m ²
Volume 75 m³
$T = 6 \min by Q_t$
Grit washer Q _m = 20 l/s
Preliminary clarifier: 1 line,
Diameter D = 8,00 m
Water depht 2,50 m
$V = 460 \text{ m}^3 \dots t = 0,59 \text{ h by } Q_t$
sludge scraper
Biological basin:
2-line, each line
Water depth T = 5,50 m
Aerob basin 1 basin = 600 m ³
Anox basin 1 basin (Denitrification) = 600 m^3
Aerob 3 basins (Nitrification) = 1.800 m^3
6x 180 pieces membrane diffusers
Volume - Aerob basin 1.200 m³
Volume - Denitrification 1.200 m ³
Volume - Nitrification 3.600 m ³
Volume - Total A + VD + VN = 6.000 m^3

2x 3 Horizontal agitator	
Recirculation pumps $2x Q = 320 l/s$	
5 compressors; 9.668 Nm³/h, 290 kW	
Final clarifier:	
2 basins	
Circular basin D = 30 m	
Water depht 4,05 m; V = $2x 2.130 \text{ m}^3$	
sludge scraper	
Phosphote precipitation:	
Simultaneous precipitation	
Quantity of row sludge:	
Row sludge 182 m³/d by 500 kg TS/d	
and 30 m³/d after primary sludge pretreatme	nt
Pre-thickeners: 2 pieces	
Diameter 7,24 m; Volume = $2x 140 \text{ m}^3$	
Rabble rakes, sludge water separation	
Secondary sludge pretreatment:	
screencloth, Conditioning by	
Polyetectrolytes $Q = 30 \text{ m}^3/\text{h}$	
Strainpress:	
$Q = 5 \text{ m}^3/\text{h}$	
Digestion chambers: 1 piece	
Truncated cone:	
D1 = 13,90 m; D2 = 2,50 m; H = 18,00 m	
Usable volume = 1.200 m ³ ;	
Digestion time 60 days	
Circulation by biogas + pumps	
Post thickeners: 2 piedes	
Diameter = 7,24 m; Volume = $2x 140 \text{ m}^3$	
Rabble rakes, sludge water separation	

Gasometer:	
Pressure tank 25 mbar	
Usable volume 270 m ³ ; H = rd. 8,0 m	
Gas flare plant:	
Capacity = 120 m³/h	
Gas compressor station:	
2 radial compressor	
Sludge dewatering:	
1 chamber filter press, Conditioning	
by Polyelectrolytes $Q = 20 \text{ m}^3/\text{h}$	
Sludge storage:	
Area 100 m ² loaded by screw conveyor	
Liquified gas installation:	
Tank V = 5 m^3 by evaporator station	
Ventilation system:	
Chemical area treatment scrubber + biofilter	
From sludge treatment: 15.000 m ³ /h	
Heating system plant by 2 boiler plants	
each 411 kW thermal capacity by switching	
automatically for methane gas or biogas	
Gas engine plant:	
2 pieces each	
P _{tot} = 223 kW; P _{el} = 83 kW; P _{th} = 123 kW	
for propane and biogas	
Desar well industrial weters	

Deep well – industrial water:

2 pieces of pumps, each 20 l/s











SEWAGE TREATMENT LINE

The sewage treatment plant was dimensioned and engineerized for a 40.000 inhabitants equivalent capacity, in the way to satisfy the needs of population in local areas, of tourism, of industry and artisan shipment, guarantying in the meanwhile higher levels in quality, with the maximum efficiency in organic pollutant load knocking down and phosphoric and nitrogen components strong reduction. The target of sewage treatment is reached with physical, biological, chemical and biochemical processes. The mechanical sewage, with a 25% organic load reduction efficiency, is assured by a spire screen, by aerated grit chamber, bar-screens and primary clarifier. After that, the sewage treated mechanically cross a series of 3 falls: in the first one, in totally oxygen absence, takes place the bio-chemical process of partial phosphoric compounds deleting, in the second one, the nitrous compounds reduction is real-

ized (denitrification) while in the last one, the bigger one, atmospheric oxygen is injected to permit la biodegradation of organic compounds and nitrous compounds oxidation (nitrification). The recycle of vented sewage, of actives sludges and the regulation of oxygen concentration, permit the creation of an ambient in which microorganisms and various nature batteries may easily do the proper work of degradation of pollutant load. These microorganisms, in bow structures, are the actives sludges that are separated by sedimentation in the big secondary clarifier. The last reduction of phosphoric compounds is obtained by simultaneous precipitation (adding chemicals agents).

The water's superior layer, now purified, flows out on toothed threshold, is analyzed by a measurement and metering station (for quality and flow rate), and flows out into Rienza river.









GAS & SLUDGES TREATMENT LINE

The sludge coming from the first clarifiers (primary sludge) is thickened mechanically by pre-thickeners. The sludge is now eliminated from secondary clarifiers and thickened mechanically by screencloth. The pre-thickened sludges are now reached at a temperature of 38°C approx and digested into an anaerobic digestion chamber. The sludges, now stabilized and neutrals, are dried with a Strain press.

During the digestion process, the microorganisms trans-

forming the organic compounds on CO2 and methane with high energetic content, available for thermal heating of digestion chambers and for factory heating. To take a solution at the gas over production, in Wasserfeld plant is provided a storage gas tank.

The gas line is composed by:

gasometer, pressurization station, gas flare, 2 heaters and 2 cogeneration groups.

VENTILATION SYSTEM

COMPONENTS AND POWER

During Wasserfeld plant engineer studies, a special importance matter was the particular attention at stinks emissions monitoring. Stink air coming from fine bar screen, is adsorbed with compressors and biologically treated into the oxidation basin. The stink air coming from the sludges treating plant is located in warehouses with the proper air treating system.

The stink air, until a flow rate of 15.000 m³/h, is chemically purified with scrubber at crossing flows system with, storing the thermal energy and biologically purified with a 532 m² sized bio filter. For sewerage system and sludges treatment were provided a total amount of 150 units divided into instrumentation, machineries, for a total amount of power consumption of approx 220 kW; the same items quantity were necessary for heating system, ventilation, air treatment, lightness systems, hydro feed exc.. For power plant, control and regulation of all these plants and systems, 25 km of bundles and cables were provided











IDA SOMPUNT Badia

CONSTRUCTION PROGRESS

Start of building: 1983

Completion: 1992

Initial operation and functional tests: December 1989

In operation: since January 1990

OPERATING DATA

Yearly quantity of sewage: $2.000.000 \text{ m}^3/a$ Sludge quantity: 1.000 tons/aProduced electrical energy: 350.000 kWh/aEfficiency: $BOD_5 = 98\%$
COD = 95%
 $N_{\odot} = 75\%$

 $\frac{N_{tot}}{P_{tot}} = 75\%$



IDA SOMPUNT Badia



MUNICIPALITIES



PERFORMANCE DATA

Capacity:	58.000 inhabitants equivalent
each	10% population
	80% from tourism
	10% from industry
Loads:	2.955 kg BOD ₅ /d
	3.905 COD/d
	446 kg N _{tot} /d
	150 kg P _{tot} /d
Sewage flow:	Daily quantity of sewage 5.000 m ³ /d
	Dry weather flow 156 l/s
	Wet weather flow 300 l/s
Quantity of sludge:	Row 27 m ³ /g
	1.300 kg/d dried matter
	After primary sludge treatment 30 m ³ /d
	After sludge dewatering 5 m³/d
Tot. effective volume:	Meccanical – biological
	treatment 9.860 m ³
	Sludge treatment 1.080 m ³
Area:	21.207 m ²

TECHNICAL DATA SEWERAGE SYSTEM

reconstruct 2014/15

Catchment area: 109 km²

Lenght: 5,16 km

Diameter: 300 mm – 400 mm

Material: PEHD

Quantity drains: 114

Quantity measuring stations: 2

Quantity pump stations: 5

TECHNICAL DATA

Emergency screening plant:
1 bar-screen
Bar spacing 3 mm
Screening plant:
2 steep grate
Bar spacing 6 mm, Q _m = 1.008 m³/h
by 1 screenings wash presses integrated
and bagging decive
Aerated grit chamber: 2-line
Grit chamber: Cross section 2x 11,50 m ²
Volume 2x 270 m³
T = 65 min by Q_t
Grit washer Q _m = 12 l/s
Preliminary clarifier: 4-line
Wide 5,0 m; Lenght 29,60 m
Wather depht = 2,40 m
$V = 4x \ 380 \ m^3 \dots t = 3,0 \ h \ by \ Q_t 0,$
longitudinal flowed, sludge scrapers
Biological basin:
4-line, each line
Wide 4,60 m
Lenght 38,00 m
Water depht = 5,00 m
4x 242 pieces plate aerator
Volume total 4x 800 = 3.600 m^3
Recirculation sludge,
Recirculation pumps $14x Q = 25 l/s$
4 compressors
3 to 1.530 Nm ³ /h, 37 kW
1 to 981 Nm³/h, 30 kW

Final clarifier: 4-basins
Lenght 9,70 m; wide 40,00 m
Water depht = 3,20 m
V = 4x 1.150 m ³ t = 3,0 h by Qt
Longitudinal flowed, chain&flight scrapers
Phosphate precipitation:
Simultaneous precipitation
Quantity of row sludge:
Row sludge 27 m³/d con 1.300 kg TS/d
and 30 m ³ /d
Pre-thickeners: 1 pieces
Diameter 7,00 m; volume = $1 \times 150 \text{ m}^3$
Rabble rakes, sludge water separation
Secondary sludge pretreatment:
Screencloth, conditioning by
polyetectrolytes $Q = 30 \text{ m}^3/\text{h}$
Digestion chambre: 2 piece
Cylindrical tank
D1 = 7,00 m; D2 = 1,30 m; H = 13,40 m
Usable volume = $2 \times 390 \text{ m}^3$;
digestion time 30 days
Circulation by pumps
Post thickeners: 1 piece
Diameter = 7,00 m; Volume = $1 \times 150 \text{ m}^3$
rabble rakes
Gasometer:
Usable volume 500 m ³ ;
H = rd. 8,0 m, D = 10,00 m
Gas flare plant:
Capacity = $600 \text{ m}^3/\text{h}$

1 screw press Conditioning by polyetectrolytes Q = $3 - 5 \text{ m}^3/\text{h}$ Sludge storage: Area: $4x 4,40 \text{ m} x 9,40 \text{ m} = 165 \text{ m}^2$; volume: $4x 25 \text{ m}^3 = 100 \text{ m}^3$ Ventilation system: Chemical area treatment (scrubber) from meccanical and sludge treatment: $15.000 \text{ m}^3/\text{o}$ Gas engine plant: 1 piece: P _{tot} = 170 kW ; P _{el} = 60 kW ; P _{th} = 110 kW 1 piece: P _{tot} = 192 kW ; P _{el} = 80 kW ; P _{th} = 112 kW Deep well – industrial water:
Conditioning by polyetectrolytes Q = $3 - 5 \text{ m}^3/\text{h}$ Sludge storage: Area: $4x 4,40 \text{ m} x 9,40 \text{ m} = 165 \text{ m}^2$; volume: $4x 25 \text{ m}^3 = 100 \text{ m}^3$ Ventilation system: Chemical area treatment (scrubber) from meccanical and sludge treatment: $15.000 \text{ m}^3/\text{o}$ Gas engine plant: 1 piece: P _{tot} = 170 kW ; P _{el} = 60 kW ; P _{th} = 110 kW 1 piece: P _{tot} = 192 kW ; P _{el} = 80 kW ; P _{th} = 112 kW Deep well – industrial water:
Q = $3 - 5 \text{ m}^3/\text{h}$ Sludge storage: Area: $4x 4,40 \text{ m} x 9,40 \text{ m} = 165 \text{ m}^2$; volume: $4x 25 \text{ m}^3 = 100 \text{ m}^3$ Ventilation system: Chemical area treatment (scrubber) from meccanical and sludge treatment: $15.000 \text{ m}^3/\text{o}$ Gas engine plant: 1 piece: $P_{tot} = 170 \text{ kW}; P_{el} = 60 \text{ kW}; P_{th} = 110 \text{ kW}$ 1 piece: $P_{tot} = 192 \text{ kW}; P_{el} = 80 \text{ kW}; P_{th} = 112 \text{ kW}$ Deep well – industrial water:
Sludge storage:Area: $4x 4,40 m x 9,40 m = 165 m^2$;volume: $4x 25 m^3 = 100 m^3$ Ventilation system:Chemical area treatment (scrubber)from meccanical and sludgetreatment: $15.000 m^3/o$ Gas engine plant:1 piece: $P_{tot} = 170 kW; P_{el} = 60 kW; P_{th} = 110 kW$ 1 piece: $P_{tot} = 192 kW; P_{el} = 80 kW; P_{th} = 112 kW$ Deep well – industrial water:
Area: 4x 4,40 m x 9,40 m=165 m ² ; volume: 4x 25 m ³ = 100 m ³ Ventilation system: Chemical area treatment (scrubber) from meccanical and sludge treatment: 15.000 m ³ /o Gas engine plant: 1 piece: $P_{tot} = 170 \text{ kW}; P_{el} = 60 \text{ kW}; P_{th} = 110 \text{ kW}$ 1 piece: $P_{tot} = 192 \text{ kW}; P_{el} = 80 \text{ kW}; P_{th} = 112 \text{ kW}$ Deep well – industrial water:
volume: $4x \ 25 \ m^3 = 100 \ m^3$ Ventilation system: Chemical area treatment (scrubber) from meccanical and sludge treatment: $15.000 \ m^3/o$ Gas engine plant: 1 piece: $P_{tot} = 170 \ kW; P_{el} = 60 \ kW; P_{th} = 110 \ kW$ 1 piece: $P_{tot} = 192 \ kW; P_{el} = 80 \ kW; P_{th} = 112 \ kW$ Deep well – industrial water:
Ventilation system:Chemical area treatment (scrubber)from meccanical and sludgetreatment: 15.000 m³/oGas engine plant:1 piece: $P_{tot} = 170 \text{ kW}; P_{el} = 60 \text{ kW}; P_{th} = 110 \text{ kW}$ 1 piece: $P_{tot} = 192 \text{ kW}; P_{el} = 80 \text{ kW}; P_{th} = 112 \text{ kW}$ Deep well – industrial water:
Chemical area treatment (scrubber) from meccanical and sludge treatment: 15.000 m ³ /o Gas engine plant: 1 piece: P _{tot} = 170 kW; P _{el} = 60 kW; P _{th} = 110 kW 1 piece: P _{tot} = 192 kW; P _{el} = 80 kW; P _{th} = 112 kW Deep well – industrial water:
from meccanical and sludge treatment: 15.000 m ³ /o Gas engine plant: 1 piece: $P_{tot} = 170 \text{ kW}; P_{el} = 60 \text{ kW}; P_{th} = 110 \text{ kW}$ 1 piece: $P_{tot} = 192 \text{ kW}; P_{el} = 80 \text{ kW}; P_{th} = 112 \text{ kW}$ Deep well – industrial water:
treatment: 15.000 m ³ /o Gas engine plant: 1 piece: $P_{tot} = 170 \text{ kW}; P_{el} = 60 \text{ kW}; P_{th} = 110 \text{ kW}$ 1 piece: $P_{tot} = 192 \text{ kW}; P_{el} = 80 \text{ kW}; P_{th} = 112 \text{ kW}$ Deep well – industrial water:
Gas engine plant:1 piece: $P_{tot} = 170 \text{ kW}; P_{el} = 60 \text{ kW}; P_{th} = 110 \text{ kW}$ 1 piece: $P_{tot} = 192 \text{ kW}; P_{el} = 80 \text{ kW}; P_{th} = 112 \text{ kW}$ Deep well – industrial water:
1 piece: $\frac{P_{tot} = 170 \text{ kW}; P_{el} = 60 \text{ kW}; P_{th} = 110 \text{ kW}}{1 \text{ piece}:}$ $P_{tot} = 192 \text{ kW}; P_{el} = 80 \text{ kW}; P_{th} = 112 \text{ kW}$ Deep well – industrial water:
$\frac{P_{tot} = 170 \text{ kW}; P_{el} = 60 \text{ kW}; P_{th} = 110 \text{ kW}}{1 \text{ piece:}}$ $\frac{P_{tot} = 192 \text{ kW}; P_{el} = 80 \text{ kW}; P_{th} = 112 \text{ kW}}{\text{Deep well - industrial water:}}$
1 piece: P _{tot} = 192 kW; P _{et} = 80 kW; P _{th} = 112 kW Deep well – industrial water:
P _{tot} = 192 kW; P _{el} = 80 kW; P _{th} = 112 kW Deep well – industrial water:
Deep well – industrial water:
•
2 pieces of pumps, each 4,45 l/s and 6,12 l/s







SEWAGE TREATMENT LINE

The sewage treatment plant was dimensioned and engineerized for a 58.000 inhabitants equivalent capacity, in the way to satisfy the needs of population in local areas, of tourism, of industry and artisan shipment, guarantying in the meanwhile higher levels in quality, with the maximum efficiency in organic pollutant load knocking down and phosphoric and nitrogen components strong reduction. The target of sewage treatment is reached with physical, biological, chemical and biochemical processes. The mechanical sewage, with a 25% organic load reduction efficiency, is assured by a spire screen, by aerated grit chamber, bar-screens and primary clarifier. After that, the sewage treated mechanically cross the biological tank in the atmospheric oxygen is injected to permit the biodegradation of organic compounds and nitrous compounds oxidation (nitrification). The recycle of vented sewage, of actives sludges and the regulation of oxygen concentration, permit the creation of an ambient in which microorganisms and various nature batteries may easily do the proper work of degradation of pollutant load. These microorganisms, in bow structures, are the actives sludges that are separated by sedimentation in the big secondary clarifier. The last reduction of phosphoric compounds is obtained by simultaneous precipitation (adding chemicals agents). The water's superior layer, now purified, flows out on toothed threshold, is analyzed by a measurement and metering station (for quality and flow rate), and flows out into Gader river.









GAS & SLUDGES TREATMENT LINE

The sludge coming from the first clarifiers (primary sludge) is thickened mechanically by a pre-thickener. The sludge is now eliminated from secondary clarifiers and thickened mechanically by screencloth. The pre-thickened sludges are now reached at a temperature of 38°C approx and digested into an anaerobic digestion chamber. The sludges, now stabilized and neutrals, are dried with a screw press.

During the digestion process, the microorganisms trans-

forming the organic compounds on CO2 and methane with high energetic content, available for thermal heating of digestion chambers and for factory heating. To take a solution at the gas over production is provided a storage gas tank.

The gas line is composed by:

gasometer, gas flare, 1 heaters and 2 cogeneration groups.

VENTILATION SYSTEM

COMPONENTS AND POWER

During Sompunt plant engineer studies, a special importance matter was the particular attenzion at stinks emossions monitoring.

Exhaust air from the pre-treatment plant is transported to the scrubber using ventilators with an output of 15,000 Nm³/h where it is then chemically cleaned.

For sewerage system and sludges treatment were provided a total amount of 150 units divided into instrumentation, machineries, for a total amount of power consumption of approx 220 kW; the same items quantity were necessary for heating system, ventilation, air treatment, lightness systems, hydro feed exc.. For power plant, control and regulation of all these plants and systems, 25 km of bundles and cables were provided.









Sludge devatering

744

Final clarifiers Tr

Final clarifiers

Transformer station ers Workshop/Garage

Digester Sludge pretreatment

Sludge pretreatment

Biological basin

Operational building

Preliminary clarifiers

Screening plant, areated grit chamber & ventilation system Gasometer

IDA BASSA VAL PUSTERIA Rio di Pusteria

CONSTRUCTION PROGRESS

Start of construction: 1994

Completion: September 1999

Beginning of operation and function tests: Oct. 1999 - Nov. 1999

In operation: since 1st December 1999

OPERATIONAL DATA

Yearly quantity of sewage: 1.430.000 m³/a Sludge quantity: 1.400 Tons/a Produced electrical energy: 716.000 kWh/a Efficiency: $\frac{BOD_5 = 99\%}{COD = 96\%}$ N = 85%

 $\frac{N_{tot} = 85\%}{P_{tot} = 84\%}$



IDA BASSA VAL PUSTERIA

Rio di Pusteria



MUNICIPALITIES













Municipality of Municipality of Rio di Pusteria

Terento Vandoies

Rodengo Falzes

PERFORMANCE DATA

Capacity:	55.000 inhabitants equivalent
each	30% population
	45% from tourism
	25% from industry
Loads:	2.000 kg BOD ₅ /d
	3.300 COD/d
	350 kg N _{tot} /d
	60 kg P _{tot} /d
Sewage:	Daily quantity of sewage: 4.000 m³/d
	Dry weather flow: 107 l/s
	Wet weather flow 300 l/s
Quantity of sludge:	row 182 m³/d
	1.400 kg/d dried matter
	After primary sludge treatment 25 m ³ /d
	After sludge dewatering 4,5 m³/d
Tot. effective volume:	meccanical – biological
	treatment 8.546 m ³
	Sludge treatment 1.716 m ³
T 1 66 11 1	25.000 3

Tot. effective volume: 25.000 m³

TECHNICAL DATA SEWERAGE SYSTEM

Catchment area: 333 km² Lenght Hauptsammler: 19,73 km Diameter: 250 mm – 500 mm Material: PVC, GFK, GG, STZ, SB Quantity drains: 343 Quantity measuring stations: 6 **Quantity Pump stationes:** 5

TECHNICAL DATA

Pump station:
3 screw conveyor, 800 mm,
Tilt angle 33°; Q _{max} 100 l/s
Screening plant: 2-line
1 bar-screen, wide 1.300 mm
Bar spacing: 10 mm; $Q_{max} = 1.080 \text{ m}^3/\text{h}$
by 1 screenings wash presses integrated
and bagging decive
Aerated grit chamber: 2-line; each line
Grit chamber: diameter = 5,30 m;
Volume 50 m ³ ; T = 6 min by Q_t
Grit washer Q _m = 16 l/s
Preliminary clarifier: 1 line
Diameter D = 18,5 m
Water depht 2,95 m
V = 844 m ³ t = 2,19 h by Q _t
sludge scraper
Biological basin: 2-line, each Line
Aerob basin 1 basin = 440 m³
Anox basin 1 basin (Denitrification) = 440 m^3
Aerob 3 basins (Nitrification) = 1.320 m^3
6x 132 pieces plate aerator
2x 123 pieces plate aerator
Volume - Aerob basin 880 m³
Volume - Denitrification 880 m ³
Volume - Nitrification 2.640 m ³
Volume - Total A + VD + VN = 4.400 m^3
4 vertical agitator
Recirculation pumps 2x Q = 190 l/s
$3 \text{ compressors each} \cdot 1.800 \text{ Nm}^3/\text{h} \cdot 45 \text{ k/M}$

Final clarifier: 2 basins Circular basin D = 25.60 m Water depht 4,00 m; V = $2x 2.043 \text{ m}^3$ sludge scraper Phosphote precipitation: Simultaneous precipitation Quantity of row sludge: Row sludge 182 m³/d by 1.500 kg TS/d and 30 m^3/d after primary sludge pretreatment **Pre-thickeners:** 1 piece Diameter 10 m: Volume = $1x 350 \text{ m}^3$ Rabble rakes, sludge water separation Primary sludge pretreatment: screencloth, Conditioning by Polyetectrolytes $Q = 15 \text{ m}^3/\text{h}$ Secondary sludge pretreatment: Disc thickener, Conditioning by Polyetectrolytes $Q = 15 \text{ m}^3/\text{h}$ Strainpress: $Q = 10 \text{ m}^3/\text{h}$ **Digestion chambers:** 1 piece Cylindrical tank D = 12,00 m; H = 11,26 mUsable volume = 1.056 m^3 Digestion time 50 days Circulation by biogas + pumps **Post thickeners:** 1 piece Diameter = 10.00 m; Volume = 1×310 m³ Rabble rakes, sludge water separation Gasometer: Cylindrical enclosure in steel construction

Gas membrane accumulator; Usable volume 300 m³; H = rd. 8,0 m Gas flare plant: Capacity = $100 \text{ m}^3/\text{h}$ Gas compressor station: 2 radial compressors 1 screw press, Conditioning by Polyetectrolytes, $Q = 3 - 5 \text{ m}^3/\text{h}$ Sludge storage: loaded by screw conveyor Ventilation system: Chemical area treatment scrubber From sludge treatment and building: $21.000 \text{ m}^3/\text{h}$ Heating system plant by 2 boiler plants each 115 kW thermal capacity by switching automatically for methane gas or biogas Gas engine plant: 2 pieces each $P_{tot} = 190 \text{ kW}; P_{el} = 60 \text{ kW}; P_{th} = 99 \text{ kW}$ for propane and biogas Deep well - industrial water: 2 pieces of pumps, each 11 l/s









SEWAGE TREATMENT LINE

The sewage treatment plant was dimensioned and engineerized for a 55.000 inhabitants equivalent capacity, in the way to satisfy the needs of population in local areas, of tourism, of industry and artisan shipment, guarantying in the meanwhile higher levels in quality, with the maximum efficiency in organic pollutant load knocking down and phosphoric and nitrogen components strong reduction. The target of sewage treatment is reached with physical, biological, chemical and biochemical processes. The mechanical sewage, with a 25% organic load reduction efficiency, is assured by a spire screen, by aerated grit chamber, bar-screens and primary clarifier. After that, the sewage treated mechanically cross a series of 5 falls: in the first one, in totally oxygen absence, takes place the bio-chemical process of partial phosphoric compounds deleting, in the second one, the nitrous compounds reduction is realized (denitrification) while in the last three, the biggest ones, atmospheric oxygen is injected to permit la biodegradation of organic compounds and nitrous compounds oxidation (nitrification). The recycle of vented sewage, of actives sludges and the regulation of oxygen concentration, permit the creation of an ambient in which microorganisms and various nature batteries may easily do the proper work of degradation of pollutant load. These microorganisms, in bow structures, are the actives sludges that are separated by sedimentation in the big secondary clarifier. The last reduction of phosphoric compounds is obtained by simultaneous precipitation (adding chemicals agents).

The water's superior layer, now purified, flows out on toothed threshold, is analyzed by a measurement and metering station (for quality and flow rate), and flows out into Rienza river.









GAS & SLUDGES TREATMENT LINE

The sludge coming from the first clarifiers (primary sludge) is thickened mechanically by a pre-thickener. The sludge is now eliminated from secondary clarifiers and thickened mechanically by disc thickener. The pre-thickened sludges are now reached at a temperature of 38°C approx and digested into an anaerobic digestion chamber. The sludges, now stabilized and neutrals, are dried with a screw press.

During the digestion process, the microorganisms trans-

forming the organic compounds on CO2 and methane with high energetic content, available for thermal heating of digestion chambers and for factory heating. To take a solution at the gas over production, in the Bassa Val Pusteria plant is provided a storage gas tank.

The gas line is composed by:

gasometer, pressurization station, gas flare, 2 heaters and 2 cogeneration groups.





VENTILATION SYSTEM

During Bassa Val Pusteria plant engineer studies, a special importance matter was the particular attention at stinks emissions monitoring. All the stronger sources and ways of stinkness (fine bar screen, aerated grift chamber, clarifier and the entire sewerage treatment plant) are positioned on warehouses with the proper air purification system.

The stink air, until a flow rate of 21.000 m³/h, is purified with scrubber at crossing flows system with, storing the thermal energy produced.

COMPONENTS AND POWER

For sewerage system and sludges treatment were provided a total amount of 120 units divided into instrumentation, machineries, for a total amount of power consumption of approx 200 kW; the same items quantity were necessary for heating system, ventilation, air treatment, lightness systems, hydro feed exc.. For power plant, control and regulation of all these plants and systems, 25 km of bundles and cables were provided.









IDA TOBL San Lorenzo di Sebato **IDA SAN CANDIDO-SESTO** San Candido **IDA WASSERFELD** Monguelfo



IDA SOMPUNT Badia **IDA BASSA VAL PUSTERIA** Rio di Pusteria



dvmeda



Floronzo / Tobel 54 - I-39030 San Lorenzo (BZ) - Tel. +39 0474 479601 - Fax +39 0474 479641 - info@arapustertal.it - www.arapustertal.it